

AGA CERTIFIED PRODUCT



JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **A.A.P Industries PTY LTD**

ABN/ACN No. (if applicable): **000 402 826**

Manufacturer: **Zhejiang Valogin Technology Co., Ltd**

Agent (if applicable): **N/A**

Type of Component: **MANUAL SHUT OFF VALVES**
MWP: 2500kPa
Temperature range: 0°C to 60°C

Model No. & Description: **V & G**
Refer to Page 2 for Model Designations

Relevant Standard(s): **AS 4617-2018**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Group Manager, Technical Operations

Certificate Authorised

Page 1 of 2

Certificate first issued: **13 December 2018**

Certificate No: **8775**

This copy valid from: **13 December 2018**

Refer specification issue: **01**

QF714/11

AGA CERTIFIED PRODUCT



Model No. & Description: **V & G**

VBBD08,VBBD10,VBBD15,VBBD20,VBBD25,VBBD32,VBBD40,VBBD50,VBBD65,VBBD80,VBBD94
VBBD08L,VBBD10L,VBBD15L,VBBD20L,VBBD25L,VBBD32L,VBBD40L,VBBD50L,VBBD65L,VBBD80L,VBBD94L
VBBD15EL,VBBD20EL,VBBD25EL,VBBD32EL,VBBD40EL,VBBD50EL
VBBDMF15TH,VBBDMF20TH,VBBDMF25TH
VBBDMF20LTH
VBBD20LTH
VGASMF50L
VGAS08TH,VGAS10TH,VGAS15TH,VGAS20TH,VGAS25TH
VGAS08,VGAS10,VGAS15,VGAS20,VGAS25,VGAS32,VGAS40,VGAS50,VGAS65,VGAS80,VGAS94
VGAS15L,VGAS20L,VGAS25L,VGAS32L,VGAS40L,VGAS50L,VGAS65L,VGAS80L,VGAS94L
VBBD15TH,VBBD20TH,VBBD25TH
VGASMF08TH,VGASMF10TH,VGASMF15TH,VGASMF20TH,VGASMF25TH
VF10,VF15,VF20

JAS-ANZ



www.jas-anz.org/register

(Refer www.aga.asn.au for more details)

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Group Manager, Technical Operations

Certificate Authorised

Page 2 of 2

Certificate first issued: **13 December 2018**

Certificate No: **8775**

This copy valid from: **13 December 2018**

Refer specification issue: **01**

QF714/11

Directory Certificate Entry

Components

Manual Shut-Off Valves

Type 1 - Isolating Valves

A.A.P. Industries Pty Ltd

(31 Monro Ave, Kirrawee, 2232 NSW AUSTRALIA Ph: (02) 9521 4433)

Relevant Standard/s:

AS 4617 | 2018 | Manually operated gas valves | 28/06/2018

V & G

8775 12.18

Manual Shut Off Valve

	<i>kPa Rating</i>
VBBD08,VBBD10,VBBD15,VBBD20,VBBD25,VBBD32,VBBD40,VBBD50,VBBD65,VBBD80,VBBD94	2500
VBBD08L,VBBD10L,VBBD15L,VBBD20L,VBBD25L,VBBD32L,VBBD40L,VBBD50L,VBBD65L,VBBD80L,VBBD94L	2500
VBBD15EL,VBBD20EL,VBBD25EL,VBBD32EL,VBBD40EL,VBBD50EL	2500
VBBDMF15TH,VBBDMF20TH,VBBDMF25TH	2500
VBBDMF20LTH	2500
VBBD20LTH	2500
VGASMF50L	2500
VGAS08TH,VGAS10TH,VGAS15TH,VGAS20TH,VGAS25TH	2500
VGAS08,VGAS10,VGAS15,VGAS20,VGAS25,VGAS32,VGAS40,VGAS50,VGAS65,VGAS80,VGAS94	2500
VGAS15L,VGAS20L,VGAS25L,VGAS32L,VGAS40L,VGAS50L,VGAS65L,VGAS80L,VGAS94L	2500
VBBD15TH,VBBD20TH,VBBD25TH	2500
VGASMF08TH,VGASMF10TH,VGASMF15TH,VGASMF20TH,VGASMF25TH	2500
VF10,VF15,VF20	2500

Working Temperature range: 0°C - 60°C

Monday, 17 December 2018