



Product Authorisation Certificate

For use in City West Water's Infrastructure Systems

Issued to

AAP Industries Pty Ltd

Authorisation:	12/595	Licence No:	SMKP21360
Australian Standard:	AS 3952:2002	WSAA Product Specification	WSA PS 267
Other Standards:		Production Authorisation	29 November 2017
		Expiry Date:	

Description of Product

Maxiflo™ Spring Hydrant Valve for water supply applications

PN 16, DN 100, Flanged end to AS/NZS 4087
Figure B5 or AS 2129 Table D



Conditions

- Where a range of items or sizes are involved, this Authorisation applies only to those items or sizes listed in the MRWA Products Web Portal <http://www.mrwa.com.au/Pages/Home.aspx>.
- This Authorisation does not refer to the effectiveness of the product and no claim shall be made through advertising, promotion or in any other way that the above products have been authorised or tested by CWW in other than the terms of this authorisation.
- The items described above are authorised for use in CWW Infrastructure systems, in accordance with the design and installation practices as detailed or referenced in the:
 - § Melbourne Retail Water Agency (MRWA) Edition of the Water Services Association of Australia (WSAA) Water Supply Code of Australia WSA 03:2012 Version 3.1;
 - § CWW's supplement to the code; and
 - § Other installation recommendations of the Manufacturer.
- AAP Industries Pty Ltd shall be responsible for assuring the quality of approved products that are supplied by AAP Industries Pty Ltd to the market. Where the approved products or parts thereof are manufactured or assembled by a third party, AAP Industries Pty Ltd shall employ systematic procedures to verify product conformance.
- The product shall be manufactured under a third party certified Quality Assurance System. All products shall be identified with the manufacturers name or trade mark.
- The products shall demonstrate satisfactory performance when installed in CWW Infrastructure system.
- CWW shall be notified in writing if:
 - § The third party certification is withdrawn, suspended or changed;
 - § Any change of the certification agency occurs;
 - § There are any changes to product design, materials, model numbers etc. or
 - § The products are to be withdrawn from sale.

4. This approval is valid for five years from the issue date of this certificate. Renewals of approval should be sought three months prior to approval expiry.

9. The products may be subjected to random quality control checks for which a charge may apply. Compliance with new Standards as they are replaced will need to be demonstrated.

10. CWW reserves the right to request additional information and / or evidence of product suitability add or vary to the conditions set out above, or if necessary, modify or withdraw the authorisation at any time.

Signed: 

Robert Jagger
Manager Standards

Date: 30 November 2012

This Certificate is issued without alteration or erasure.